



JAN 24 2008

813 cust_id

308257 insp_id

5358 site_id

INSPECTION REPORT

**NORTH CAROLINA A&T STATE
UNIVERSITY**

Customer ID: 813

Certificate: 55-R-0022

Site: 001

**NORTH CAROLINA A&T STATE
UNIVERSITY**

**LAB. ANIMAL RESOURCE UNIT
116 WEBB HALL
GREENSBORO, NC 27411**

Inspection

Type: ROUTINE INSPECTION

Date: JAN-14-2008

3.1 (c)

HOUSING FACILITIES, GENERAL.

General requirements. The surfaces of housing facilities—including houses, dens, and other furniture-type fixtures and objects within the facility—must be constructed in a manner and made of materials that allow them to be readily cleaned and sanitized, or removed or replaced when worn or soiled. Interior surfaces and any surfaces that come in contact with dogs or cats must:

(i) Be free of excessive rust that prevents the required cleaning and sanitization, or that affects the structural strength of the surface; and

(ii) Be free of jagged edges or sharp points that might injure the animals.

(2) Maintenance and replacement of surfaces. All surfaces must be maintained on a regular basis. Surfaces of housing facilities—including houses, dens, and other furniture-type fixtures and objects within the facility—that cannot be readily cleaned and sanitized, must be replaced when worn or soiled.

****Floor and wall areas directly around clean end of tunnel washer have peeling and cracked paint. Wallboard is deteriorating around floor joint from water exposure. These areas are not easily sanitized and should be repaired. Correct by June 15, 2008.**

Prepared By:


F BINKLEY, D.V.M., USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL OFFICER Inspection ID: 1020

Date:

JAN-14-2008

Received By:

Date:

JAN-14-2008

Title: