



INSPECTION REPORT

UNIVERSITY OF NEBRASKA,
OMAHA

Customer ID: 1553

Certificate: 47-R-0021

Site: 001

UNIVERSITY OF NEBRASKA-

5001 DODGE ST
OMAHA, NE 68182

Inspection

Type: ROUTINE INSPECTION

Date: MAY-16-2006

3.75 (c) (2)

HOUSING FACILITIES, GENERAL.

Maintenance and replacement of surfaces. All surfaces must be maintained on a regular basis. Surfaces of housing facilities ... - that cannot be readily cleaned and sanitized, must be replaced when worn or soiled.

Room 528F

There were 2 areas on the north wall with defects/chipping in the paint that expose the drywall underneath. These areas should be resealed/repainted to provide for appropriate cleaning and sanitization.

(Correct this item by June 16, 2006)

Prepared By:

RUTH BAKKER, V.M.O., USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL OFFICER, Inspector ID: 4029

Date:

MAY-16-2006

Received By:

Date:

MAY-16-2006

Title: